

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012069.01  
DATE: 07/29/2014  
CERTIFICATION PROGRAM: Structural  
COMPANY: All Seasons  
CODE: 353-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>All Seasons Commercial Division, Inc.</b> <b>1293 N. Harvey Mitchell Parkway</b> <b>Bryan, TX 77803</b>	<b>Series "E4000FO Fixed Frame Offset"</b>  <b>Aluminum Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1219mm(48") H-3048mm(120") DLO: W-1119mm(44.06") H-1432mm(56.38")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class AW-PG120 1219 x 3048 (48 x 120)-FW</b> <b>Design Pressure: 5745 Pa (120 psf)</b> Water Penetration Resistance Test Pressure: 576 Pa (12 psf)

Product Tested By: Construction Consulting Laboratory, International  
Report No: CCLI 14-111  
Expiration Date: July 31, 2018

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shu", is written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122