

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013628-R1  
**DATE:** 03/08/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** All Seasons  
**CODE:** 353-1  
**REVISION DATE:** 02/06/2018

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>All Seasons Commercial Division, Inc.</b> <b>1293 N. Harvey Mitchell Parkway</b> <b>Bryan, TX 77803</b>	<b>Series "3250"</b>  <b>Aluminum Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1529mm(60.19") H-2515mm(99") DLO: W-1446mm(56.94") H-2432mm(95.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class AW-PG80 1529 x 2515 (60 x 99)-FW</b> <b>Design Pressure: ±3840 Pa (80 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12 psf)</b>

Product Tested By: Construction Consulting Laboratory, International  
Report No: CCLI 17-004  
Expiration Date: **January 31, 2021**

Administrator's Signature: \_\_\_\_\_

## **NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway**  
**Hayes, VA 23072**  
**Tel: (804) 684-5124**  
**Fax: (804) 684-5122**