

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013985
DATE: 03/13/2018
CERTIFICATION PROGRAM: Structural
COMPANY: All Seasons
CODE: 353-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
All Seasons Commercial Division, Inc. 1293 N. Harvey Mitchell Parkway Bryan, TX 77803	Series "2000 Fixed Frame" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass-Int-Laminate-1/8" Annealed Glass/0.090" SentryGlas Plus by Kuraray/1/8" Annealed Glass/Ext-1/4" Annealed Glass Frame: W-1219mm(48") H-2134mm(84") DLO: W-1118mm(44.25") H-2038mm(80.25")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 ASTM E1886-05/E1996-05b AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Design Pressure: ±3840 Pa (80 psf) Missile Level D-Wind Zone 4 Class AW-PG80 1219 x 2134 (48 x 84)-FW Water Penetration Resistance Test Pressure: 730 Pa (15 psf)

Product Tested By: Construction Consulting Laboratory, International/NCTL
Report No: CCLI 17-105/NCTL-110-15901-1
Expiration Date: May 31, 2021

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122