

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014148-R1
DATE: 07/11/2018
CERTIFICATION PROGRAM: Structural
COMPANY: All Seasons
CODE: 353-1
REVISION DATE: 09/01/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
All Seasons Commercial Division, Inc. 1293 N. Harvey Mitchell Parkway Bryan, TX 77803	Series "3250" Aluminum Fixed Window (Fin or Finless Mounted) Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1529mm(60.2") H-2515mm(99.02") DLO: W-1446mm(56.93") H-2432mm(95.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG80 1529 x 2515 (60 x 99)-H Design Pressure: ±3830 Pa (80 psf) Water Penetration Resistance Test Pressure: 580 Pa (12 psf)

Product Tested By: Construction Consulting Laboratory, International
Report No: CCLI 17-004
Expiration Date: **January 31, 2025**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122