

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014148.01-R2  
**DATE:** 07/11/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** All Seasons  
**CODE:** 353-2  
**REVISION DATE:** 01/29/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>All Seasons Commercial Division, Inc.</b> <b>400 Ambassador Row</b> <b>Longview, TX 75604</b>	<b>Series "3250"</b> <b>Aluminum Fixed Window</b> <b>(Fin or Finless Mounted)</b>  Configuration: O Glazing: IG-1/4" Annealed Glass/1/8" Annealed Glass/0.090" Kuraray SGP Interlayer/1/8" Annealed Glass  Frame: W-1219mm(47.99") H-2438mm(95.98") DLO: W-1124mm(44.25") H-2343mm(92.24")

SPECIFICATION	PRODUCT RATING
<b>AAMA 506-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>ASTM E1886-05/E1996-05b</b>	<b>Class AW-PG75 1219 x 2438 (48 x 96)-FW</b> <b>Design Pressure: ±3600 Pa (75 psf)</b> Water Penetration Resistance Test Pressure: 580 Pa (12 psf) <b><u>ASTM E1886-05/E1996-05b Results:</u></b> <b>Positive Design Pressure: 3600 Pa (75 psf)</b> <b>Negative Design Pressure: 4080 Pa (85 psf)</b> <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: Construction Consulting Laboratory, International  
Report No: CCLI 18-058/CCLI 17-004  
Expiration Date: May 31, 2028

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)