

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013903.01  
**DATE:** 07/11/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** All Seasons  
**CODE:** 353-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>All Seasons Commercial Division, Inc.</b></p> <p><b>1293 N. Harvey Mitchell Parkway</b></p> <p><b>Bryan, TX 77803</b></p>	<p><b>Series "3250"</b></p> <p><b>Aluminum Single Hung Window</b></p> <p><b>(Fin or Finless Mounted)</b></p> <p>Configuration: O/X                      Glazing: IG-1/4" Annealed Glass/1/8" Annealed Glass/0.090" Kuraray SGP Interlayer/1/8" Annealed Glass</p> <p>Frame: W-1524mm(60")    H-2134mm(84.02")</p> <p>Sash: W-1468mm(57.19")    H-1051mm(41.38")</p> <p>DLO: W-1397mm(55")    H-940mm(37")</p>

SPECIFICATION	PRODUCT RATING
<p><b>AAMA 506-08</b></p> <p><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b></p> <p><b>ASTM E1886-05/E1996-05b</b></p>	<p><b>Class AW-PG75 1524 x 2134 (60 x 84)-H</b></p> <p><b>Design Pressure: ±3600 Pa (75 psf)</b></p> <p>Water Penetration Resistance Test Pressure: 580 Pa (12 psf)</p> <p><b><u>ASTM E1886-05/E1996-05b Results:</u></b></p> <p><b>Positive Design Pressure: 3600 Pa (75 psf)</b></p> <p><b>Negative Design Pressure: 4080 Pa (85 psf)</b></p> <p><b>Wind Zone 4 - Missile Level D</b></p>

Product Tested By: Construction Consulting Laboratory, International  
 Report No: CCLI 18-057/CCLI 17-164  
 Expiration Date: May 31, 2022

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S.M.' or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
 Fax: (804) 684-5122