## **NOTICE OF PRODUCT CERTIFICATION**



CERTIFICATION NO: NI013903.01-R2

**DATE:** 07/11/2018

**CERTIFICATION PROGRAM:** Structural

**COMPANY:** All Seasons

**CODE:** 353-2

**REVISION DATE:** 01/29/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
All Seasons Window & Door Mfg., Inc.	Series "3250"
400 Ambassador Row	Aluminum Single Hung Window
Longview, TX 75604	(Fin or Finless Mounted)
	Configuration: O/X Glazing: IG-1/4" Annealed Glass/1/8" Annealed Glass/0.090" Kuraray SGP Interlayer/1/8" Annealed Glass
	Frame: W-1524mm(60") H-2134mm(84.02")
	Sash: W-1473mm(58") H-1051mm(41.38")
	DLO: W-1397mm(55") H-940mm(37")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/E1996-05b	Class AW-PG75 1524 x 2134 (60 x 84)-H  Design Pressure: ±3600 Pa (75 psf)  Water Penetration Resistance Test Pressure: 580 Pa (12 psf)  ASTM E1886-05/E1996-05b Results:  Positive Design Pressure: 3600 Pa (75 psf)  Negative Design Pressure: 4080 Pa (85 psf)  Wind Zone 4 - Missile Level D

Product Tested By: Construction Consulting Laboratory, International

Report No: CCLI 18-057/CCLI 17-164

Expiration Date: May 31, 2028

Administrator's Signature: \_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124/Email: nami@namiinc.com NOPC-03/30/2023