

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013954.05-R2
DATE: 02/08/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern Arch
CODE: 1783-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "650 Multi-Slide/Pocket Door" Vinyl Sliding Glass Door Configuration: OXXXXX Glazing: Insulating Glass-Ext-0.1875" Tempered/Laminate- 0.1875" Annealed/0.090" SentryGlas Plus by Kuraray/0.1875" Annealed Frame: W-7366mm(290") H-2438mm(96") Panel: W-1276mm(50.25") H-2356mm(92.75") DLO: W-1054mm(41.5") H-2140mm(84.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/E1996-05/09	Class LC-PG70 7366 x 2435 (290 x 96)-SD Design Pressure: ±3351 Pa (70 psf) 3.285" Sill Riser: Water Penetration Resistance Test Pressure: 504 Pa (10.5 psf) 3.785" Sill Riser: Water Penetration Resistance Test Pressure: 576 Pa (12.0 psf) Wind Zone 4-Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4092-01 (Spec 4,12,13)
Expiration Date: March 31, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023