## **NOTICE OF PRODUCT CERTIFICATION**



CERTIFICATION NO: NI013954.25-R3

**DATE:** 04/06/2020

**CERTIFICATION PROGRAM:** Structural

**COMPANY:** Eastern Arch

CODE: <u>1783-1</u>

**REVISION DATE:** <u>10/16/2023</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems	Series "650 Multi-Slide/Pocket Door"
16341 Domestic Avenue	Impact Vinyl Sliding Glass Door
Ft. Myers, FL 33912	(w/P-Hook Jamb)
	Configuration: XXXX Glazing: IG-3/16" Tempered Glass/3/16" Annealed Glass/0.090" Kuraray America Trosifol PVB Interlayer/3/16" Annealed Glass
	Frame: W-4909mm(193.25") H-2438mm(96")
	Panel: W-1276mm(50.25") H-2357mm(92.81")
	DLO: W-1099mm(43.25") H-2180mm(85.81")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/12/E1996-05/09/12	Class CW-PG45 4909 x 2438 (193 x 96)-SD  Design Pressure: ±2160 Pa (45 psf)  0.522" Sill Riser Water Penetration Resistance Test Pressure: 432 Pa (9.0 psf)
AS TWI E1660-03/12/E1770-03/07/12	1.44" Sill Riser Water Penetration Resistance Test Pressure: 576 Pa (12.0 psf) 1.94" Sill Riser Water Penetration Resistance Test Pressure: 720 Pa (15.0 psf)  ASTM E1886/E1996 Impact Rating
	Design Pressure: ±2400 Pa (50 psf)
	Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories Report No: NCTL-210-4164-02 (Spec2)/W-1959

Expiration Date: April 30, 2027

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124/Email: nami@namiinc.com

NOPC-03/30/2023