

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014145-R2
DATE: 07/11/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern Arch
CODE: 1783-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "7000" Aluminum Sliding Glass Door Configuration: OXXX Glazing: Monolithic - 3/16" Annealed Glass/0.090" Eastman Saflex PVB Interlayer/3/16" Annealed Glass or IG - 3/16" Tempered Glass/3/16" Annealed Glass/0.090" Eastman Saflex PVB Interlayer/3/16" Annealed Glass Frame: W-4877mm(192") H-2438mm(96") DLO: W-1092mm(43") H-2203mm(86.75")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2873 Pa (60 psf) Water Penetration Resistance Test Pressure: 431 Pa (9.0 psf) Large Missile Impact Rated

Product Tested By: Blackwater Testing, Inc.
Report No: BT-EMS-17-003
Expiration Date: April 30, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023