

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014145.01-R2  
**DATE:** 07/11/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Eastern Arch  
**CODE:** 1783-1  
**REVISION DATE:** 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b> <b>16341 Domestic Avenue</b> <b>Ft. Myers, FL 33912</b>	<b>Series "7000"</b> <b>Aluminum Sliding Glass Door</b>  Configuration: XXXX Glazing: Monolithic - 3/16" Annealed Glass/0.090" Eastman Saflex PVB Interlayer/3/16" Annealed Glass or IG - 3/16" Tempered Glass/3/16" Annealed Glass/0.090" Eastman Saflex PVB Interlayer/3/16" Annealed Glass  Frame: W-5271mm(207.5") H-2438mm(96") DLO: W-1127mm(44.38") H-2203mm(86.75")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±2873 Pa (60 psf)</b> Water Penetration Resistance Test Pressure: 431 Pa (9.0 psf) <b>Large Missile Impact Rated</b>

Product Tested By: Blackwater Testing, Inc.  
Report No: BT-EMS-17-003  
Expiration Date: April 30, 2027

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S.M.D.' or similar, written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023