

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014145.02
DATE: 11/02/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern Arch
CODE: 1783-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "7000" Aluminum Sliding Glass Door Configuration: OXXX Glazing: Insulated Glass (Tempered) Frame: W-4877mm(192") H-2438mm(96") DLO: W-1092mm(43") H-2203mm(86.75")

SPECIFICATION	PRODUCT RATING
TAS 202-94	Design Pressure: ±2873 Pa (60 psf) Water Penetration Resistance Test Pressure: 431 Pa (9.0 psf)

Product Tested By: Blackwater Testing, Inc.
Report No: BT-EMS-17-003/W-2091
Expiration Date: April 30, 2027

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com