

# Hallmark® Certificate of Conformance and License (CCL)



JELD-WEN INC.  
401 Harbor Isles Boulevard  
Klamath Falls, OR 97601

Mfr ID: 419  
For more Information visit [www.amscert.com](http://www.amscert.com)  
Website: WWW.JELD-WEN.COM  
TEL: (541) 882-3451

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
419-H-1125.00	Siteline or W-5500 Wood Casement Pocket Window	101/I.S.2/A440-11	Class LC-PG35; Size Tested 914mm x 2134mm (36in x 84 in) Type-C; DP +35/-35 psf	914mm	2134mm	H9984.03-301-47-r0	4/23/2018	2/21/2028

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)