

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013458-R1  
**DATE:** 12/30/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Quaker  
**CODE:** 031-1  
**REVISION DATE:** 05/07/2018

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Quaker Window Products</b> <b>504 Highway 63 South</b> <b>Freeburg, MO 65035</b>	<b>Series "M-600 Modern-Vu"</b> <b>Aluminum Casement Window</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-1219mm(48") H-2134mm(84") Vent: W-1175mm(46.25") H-2089mm(82.25") DLO: W-1067mm(42") H-1981mm(78")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class AW-PG70 1219 x 2134 (48 x 84)-C</b> <b>Design Pressure: ±3360 Pa (70 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)</b>

Product Tested By: Architectural Testing, Inc.  
Report No: G3075.01-801-47  
Expiration Date: September 30, 2028

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122