

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015457.01-R1  
**DATE:** 08/15/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Quaker  
**CODE:** 031-1  
**REVISION DATE:** 07/24/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Quaker Window Products</b> <b>504 Highway 63 South</b> <b>Freeburg, MO 65035</b>	<b>Series "M600"</b> <b>Aluminum Fixed/Awning Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-2438mm(96") Vent: W-1445mm(56.88") H-1140mm(44.88") DLO: W-1429mm(56.25") H-1189mm(46.81")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class AW-PG70 1524 x 2438 (60 x 96)-AP</b> <b>Design Pressure: ±3360 Pa (±70 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)</b>

Product Tested By: Intertek, LLC  
Report No: L5050.01-801-44-R1/W-2043  
Expiration Date: **April 30, 2028**

Administrator's Signature:  \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)