

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015457.04-R1  
**DATE:** 01/05/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Quaker  
**CODE:** 031-1  
**REVISION DATE:** 07/24/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Quaker Window Products</b> <b>504 Highway 63 South</b> <b>Freeburg, MO 65035</b>	<b>Series "M700"</b> <b>Aluminum Awning/Fixed Window</b>  (w/ or w/o Sub-Frame)  Configuration: X/O Glazing: IG-1/4" Annealed Glass/1/8" Annealed Glass/0.090 Kuraray PVB Interlayer/1/8" Annealed Glass  Frame: W-1524mm(60") H-2438mm(96")  w/Sub-Frame: W-1600mm(63") H-2515mm(99")  AP DLO: W-1337mm(52.63") H-1032mm(40.63")  FW DLO: W-1429mm(56.25") H-1189mm(46.81")

SPECIFICATION	PRODUCT RATING
<b>AAMA 506-16</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>ASTM E1886-13a/E1996-17</b>	<b>Class AW-PG70 1524 x 2438 (60 x 96)-AP</b> <b>Design Pressure: ±3360 Pa (±70 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Intertek, LLC  
Report No: L5048-01-801-44-R5/L5050.01-801-44-R1/W-2059  
Expiration Date: **November 30, 2028**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)