

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413


For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
413-H-1292.26	Heritage French Outswing Door 6080 w/Transom 6026, SP (R&D #19028)	101/I.S.2/A440-17	Class LC-PG25; Size Tested 1902mm x 2504mm Type-SHD; DP +25/-25 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A3	1902mm	2504mm	ESP031064P-2438	9/18/2019	5/31/2029
413-H-1292.27	Heritage French Outswing Door 6080 w/Transom 6026, SP (R&D #19028)	101/I.S.2/A440-17	Class LC-PG25; Size Tested 1902mm x 749mm Type-TR; DP +25/-25 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A3	1902mm	749mm	ESP031064P-2438	9/18/2019	5/31/2029
413-H-1292.28	Heritage French Outswing Door 6080 w/Transom 6026, SP (R&D #19028)	101/I.S.2/A440-17	Class LC-PG25; Size Tested 1902mm span/1627mm tributary width (74.88 in. span/64.05 in. trib width) Type-MA (Combination Horizontal Mull); DP +25/-25 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A3	1627mm	1902mm	ESP031064P-2438	9/18/2019	5/31/2029

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com