## NOTICE OF PRODUCT CERTIFICATION •



**CERTIFICATION NO:** NI013998.01-R2

**DATE:** 03/24/2018

**CERTIFICATION PROGRAM:** Structural

COMPANY: Quaker

**CODE:** 031-1

**REVISION DATE:** 02/08/2021

To verify that the "Notice of Product Certification" is valid, please visit <a href="www.NAMICertification.com">www.NAMICertification.com</a> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products	Series "M600 Modern-Vu" In-Swing
504 Highway 63 South	Aluminum Architectural Terrace Door
Freeburg, MO 65035	
	Configuration: X Glazing: Insulating Glass (Tempered)
	Frame: W-1219mm(48") H-2438mm(96")
	Panel: W-1170mm(46.07") H-2389mm(94.07")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG50 1219 x 2438 (48 x 96)-ATD  Design Pressure: ±2400 Pa (50 psf)  Water Penetration Resistance Test Pressure: 480 Pa (10.03 psf)

Product Tested By: Intertek

Report No: H6944.01-801-44
Expiration Date: **Novermber 30, 2031** 

Administrator's Signature: \_

She

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Fax: (804) 684-5122