

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014954.03-R4
DATE: 08/16/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 10/17/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC)

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "M700 OS-C" Outswing Aluminum Impact Architectural Terrace Door Configuration: X Glazing: IG- 3/16" Tempered Glass/1/8" Annealed Glass/0.090" SentryGuard Interlayer/1/8" Annealed Glass Frame: W-1219mm(48") H-2438mm(96") Panel: W-1172mm(46.13") H-2391mm(94.13") DLO: W-962mm(37.88") H-2188mm(86.13")

SPECIFICATION	PRODUCT RATING
AAMA 506-16 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-17/E1996-17	Class AW-PG70 1219 x 2438 (48 x 96)-ATD Design Pressure: ±3360 Pa (±70 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Wind Zone 3 - Missile Level D

Product Tested By: Intertek, PLC
Report No: L7266.01-801-44/L0767.01-801-47
Expiration Date: **July 31, 2030**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023