

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013310.07-R1
DATE: 09/24/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 11/17/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 8989 North Loop East, Suite 800 Houston, TX 77029	Series "SLPS" Outswing Glazed Fiberglass Side-Hinged Patio Door (w/Head Frame & Jamb Combines Soft PVC) Configuration: OXX/O Glazing: IG-1/8" Tempered Glass/1/8" Tempered Glass/0.090" Kuraray PVB Interlayer/1/8" Tempered Glass Frame: W-3720mm(146.44") H-2469mm(97.19") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-635mm(25") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±1915 Pa (40 psf) Water Penetration Resistance Test Pressure: 287 Pa (6.0 psf) Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4112-04
Expiration Date: **July 31, 2026**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com