

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014261-R3
DATE: 11/13/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Regency
CODE: 750-1
REVISION DATE: 04/04/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. 2000 Locust Gap Highway Mount Carmel, PA 17851	Series "8313" Vinyl Tilt Double Hung Window Configuration: X/X Glazing: Insulating Glass (Tempered) Frame: W-1346mm(53") H-1956mm(77") Sash: W-1270mm(50") H-940mm(37") DLO: W-1189mm(46.8") H-843mm(33.19")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 TAS 202-94	Class LC-PG50 1346 x 1956 (53 x 77)-H Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-21524-1/NCTL-110-21524-2/W-1901/W-1979
Expiration Date: **October 31, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com