

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015628.01  
**DATE:** 08/22/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Croft  
**CODE:** 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS   | PRODUCT DESCRIPTION  |
|--|--|
| <b>Croft, LLC</b><br><b>1800 North Clark Avenue</b><br><b>Magnolia, MS 39652</b> | <b>Series "30W"</b><br><b>Vinyl Fixed Window</b><br><br>Configuration: O<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-1829mm(72") H-1829mm(72")<br>DLO: W-1695mm(66.75") H-1695mm(66.75") |

| SPECIFICATION                          | PRODUCT RATING   |
|--|--|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> | <b>Class R-PG30 1829 x 1829 (72 x 72)-FW</b><br><b>Design Pressure: ±1440 Pa (30 psf)</b><br>Water Penetration Resistance Test Pressure: 330 Pa (6.89 psf) |

Product Tested By: Architectural Testing, Inc.  
Report No: B9753.01-801-47  
Expiration Date: August 31, 2026

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)