

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015640.01-R2
DATE: 07/12/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Croft
CODE: 1887-1
REVISION DATE: 03/06/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Croft, LLC 1800 North Clark Avenue Magnolia, MS 39652	Series "60" Vinyl Sliding Glass Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1969mm(71.5") H-2019mm(79.5") Panel: W-927mm(36.5") H-1957mm(77.06") DLO: W-806mm(31.75") H-1830mm(72.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG30 1829 x 2007 (72 x 79)-SD Design Pressure: ±1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Architectural Testing, Inc.
Report No: C5716.01-801-47 (Specimen 2)
Expiration Date: **July 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com