

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014365  
**DATE:** 03/02/2019  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** All Seasons  
**CODE:** 353-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>All Seasons Commercial Division, Inc.</b> <b>1293 N. Harvey Mitchell Parkway</b> <b>Bryan, TX 77803</b>	<b>Series "3250"</b> <b>Aluminum Horizontal Sliding Window</b> <b>(Fin or Finless Mounted)</b>  Configuration: XO Glazing: IG - 1/4" Annealed Glass/1/8" Annealed Glass/0.090" Kuraray SGP Interlayer/1/8" Annealed Glass  Frame: W-2438mm(96")      H-1524mm(60") Panel: W-1219mm(48")      H-1365mm(53.75") DLO: W-1111mm(43.75")      H-1356mm(53.38")

SPECIFICATION	PRODUCT RATING
<b>AAMA 506-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>ASTM E1886-05</b> <b>ASTM E1996-05b</b>	<b>Class CW-PG50 2438 x 1524 (96 x 60)-HS</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 479 Pa (10 psf)</b> <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: Construction Consulting Laboratory, International  
Report No: CCLI 18-059  
Expiration Date: **June 30, 2022**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122