

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014365-R2  
DATE: 03/02/2019  
CERTIFICATION PROGRAM: Structural  
COMPANY: All Seasons  
CODE: 353-2  
REVISION DATE: 01/29/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>All Seasons Window &amp; Door Mfg., Inc.</b> <b>400 Ambassador Row</b> <b>Longview, TX 75604</b>	<b>Series "3250"</b> <b>Aluminum Horizontal Sliding Window</b> <b>(Fin or Finless Mounted)</b>  Configuration: XO Glazing: IG - 1/4" Annealed Glass/1/8" Annealed Glass/0.090" Kuraray SGP Interlayer/1/8" Annealed Glass  Frame: W-2438mm(96") H-1524mm(60") Panel: W-1219mm(48") H-1365mm(53.75") DLO: W-1111mm(43.75") H-1356mm(53.38")

SPECIFICATION	PRODUCT RATING
<b>AAMA 506-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>ASTM E1886-05</b> <b>ASTM E1996-05b</b>	<b>Class CW-PG50 2438 x 1524 (96 x 60)-HS</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 479 Pa (10 psf)</b> <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: Construction Consulting Laboratory, International  
Report No: CCLI 18-059  
Expiration Date: June 30, 2028

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi D", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)