

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013657.02-R3  
**DATE:** 03/14/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**DATE:** 02/11/2022

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Architectural Fiberglass Glazed Inswing</b> <b>Door w/Sidelites</b>  <b>Configuration: OXO</b> <b>Glazing: Insulating Glass (Tempered)</b>  Frame: W-1997mm(78.63") H-2489mm(98") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-536mm(21.12") H-1603mm(63.12")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330-02</b>	<b>Design Pressure: 1915 Pa (40 psf)</b> <b>Negative Design Pressure: 2154 Pa (45 psf)</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01681764/W-1848  
Expiration Date: March 31, 2026

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122