

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013685.02-R2  
**DATE:** 04/17/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 02/16/2022

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "600"</b> <b>Architectural Fiberglass Opaque Inswing</b> <b>Side-Hinged Door</b> <b>(Arch Top)</b> <b>Configuration: X</b>  Frame: W-1105mm(43.5") H-2486mm(97.88") Panel: W-1060mm(41.75") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330-02/E331-00/E283-04</b> <b>ASTM E1886-05</b> <b>ASTM E1996-09</b>	<b>Design Pressure: 3591 Pa (75 psf)</b> <b>Negative Design Pressure: 4070 Pa (85 psf)</b> <b>Water Penetration Resistance Test Pressure: 0 Pa (0 psf)</b> <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01681715  
Expiration Date: April 30, 2026

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)