

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013685.05-R2
DATE: 04/17/2017
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 02/16/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Mastergrain Entry Door" Architectural Fiberglass Opaque Inswing Side-Hinged Door Configuration: X Frame: W-953mm(37.5") H-2496mm(97.88") Panel: W-908mm(35.75") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
ASTM E330-02/E331-00/E283-04 ASTM E1886-05 ASTM E1996-09	Design Pressure: 3591 Pa (75 psf) Negative Design Pressure: 4070 Pa (85 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf) Wind Zone 4 - Missile Level D

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01681715
Expiration Date: April 30, 2026

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com