

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013685.13-R3  
DATE: 04/17/2017  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1  
REVISION DATE: 02/16/2022

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Mastergrain Entry Door"</b> <b>Architectural Fiberglass Opaque Outswing</b> <b>Side-Hinged Double Door</b> <b>w/Mulled Sidelites</b>  Configuration: OXXO Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass  Frame: W-3791mm(149.25") H-2461mm(96.88") Panel: W-908mm(35.75") H-2413mm(95") DLO: W-521mm(20.5") H-1988mm(78.25")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330-02/E331-00/E283-04</b> <b>ASTM E1886-05</b> <b>ASTM E1996-09</b>	<b>Design Pressure: 2394 Pa (50 psf)</b> <b>Negative Design Pressure: 2394 Pa (50 psf)</b> Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf) <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01681715/W-1849  
Expiration Date: April 30, 2026

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)