

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013685.16-R2
DATE: 04/17/2017
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 02/16/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Craftsman" Architectural Fiberglass Glazed Inswing Side-Hinged Door Configuration: X Glazing: IG-1/4" Tempered Glass/3/16" Annealed Glass/0.090" Saflex PVB Interlayer/3/16" Annealed Glass Frame: W-953mm(37.5") H-2083mm(82") Panel: W-908mm(35.75") H-2007mm(79") DLO: W-578mm(20.75") H-356mm(14")

SPECIFICATION	PRODUCT RATING
ASTM E330-02/E331-00/E283-04 ASTM E1886-05 ASTM E1996-09	Design Pressure: 3112 Pa (65 psf) Negative Design Pressure: 3352 Pa (70 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf) Wind Zone 4 - Missile Level D

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01681715
Expiration Date: **April 30, 2026**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com