

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.44-R1
DATE: 08/27/2019
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/27/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Glazed Fiberglass In-Swing Direct Set Transom Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-2528mm(99.5") H-611mm(24.06") DLO: W-2461mm(96.88") H-543mm(21.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class LC-PG65 2528 x 611 (100 x 24)-TR Design Pressure: 3120 Pa (65 psf) Positive Design Pressure: 3120 Pa (65 psf) Negative Design Pressure: 3360 Pa (70 psf) Water Penetration Resistance Test Pressure: 510 Pa (10.65 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek Group, PLC
Report No: J7830.01-301-47
Expiration Date: May 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com