NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014535.01

DATE: 10/17/2019

CERTIFICATION PROGRAM: Structural

COMPANY: Renaissance

CODE: <u>2592-1</u>

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Renaissance Windows & Doors, Inc.	Series "8500" Triple
13340 International Parkway	Vinyl Single Hung Window
Jacksonville, FL 32218	
	Configuration: O/X O/X O/X Glazing: Insulating Glass (Annealed)
	Frame: W-2762mm(108.75") H-1829mm(72")
	Sash: W-845mm(33.25") H-889mm(35")
	DLO: W-768mm(30.25") H-813mm(32")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG40 2762 x 1829* (109 x 72*)-H Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resisitance Test Pressure: 360 Pa (7.5 psf)

Product Tested By: National Certified Testing Laboratories, Inc. Report No: NCTL-210-4105-02A/ NCTL-210-4105-02

Expiration Date: October 31, 2023

Shi

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Fax: (804) 684-5122