

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014535.02
DATE: 10/17/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Renaissance
CODE: 2592-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Renaissance Windows & Doors, Inc. 13340 International Parkway Jacksonville, FL 32218	Series "8500" Twin Vinyl Single Hung Window Configuration: O/X O/X Glazing: Insulating Glass (Annealed) Frame: W-2451mm(96.5") H-1829mm(72") Sash: W-1156mm(45.5") H-889mm(35") DLO: W-1099mm(43.25") H-819mm(32.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG35 2451 x 1829 (97 x 72)-H Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-210-4105-04
Expiration Date: **October 31, 2023**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122