

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014540
DATE: 10/17/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Renaissance
CODE: 2592-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Renaissance Windows & Doors, Inc. 13340 International Parkway Jacksonville, FL 32218	Series "9700" Vinyl Single Hung Window Configuration: O/X Glazing: IG-1/8" Annealed Glass /1/8" Annealed Glass/0.090" Kuraray PVB Interlayer/1/8" Annealed Glass Frame: W-1219mm(48") H-1880mm(74") Sash: W-1156mm(45.5") H-889mm(35") DLO: W-1105mm(43.5") H-870mm(34.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05 ASTM E1996-05/09	Class R-PG50 1219 x 1880 (48 x 74)-H Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf) Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4128-02
Expiration Date: **October 31, 2023**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122