



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

Lippert Components, Inc. dba Kinro Windows
3501 County Road 6 East
Elkhart, IN 46514

Attn: Rob Luter

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 & A440S1-09 LC-PG40*-2426x2019 (96x80)-SD					
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED		
Lippert Components, Inc. dba Kinro Windows Code: KIN	18676	1700 SGD (PVC)(OX)(OG)(INS GL) (MODIF)(REINF)(ASTM)	<u>FRAME</u> 2426 mm x 2019 mm (8'0" x 6'8")	<u>PANEL</u> 1229 mm x 1940 mm (4'0" x 6'4")	
Design Pressure (psf): +40/-40	Design Pressure (Pa): +1920/-1920	Water Test Pressure (Pa): 360	Canadian Air Infiltration/Exfiltration: A3		

This Certification will expire **December 17, 2029 (extended from December 17, 2024 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Molimo, LLC**

Report No.: **2179.02-109-12**

Date of Report: **January 17, 2020**

Evaluated for Certification: **July 25, 2023**

Associated Laboratories, Inc.

Authorized for Certification: **July 25, 2023**

Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)