

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014524.10
DATE: 12/01/2020
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Auraline Composite" Composite Awning CHS 4 Wide Casement Windows (w/Nail Fin or Thru-Frame) Configuration: XXXX Glazing: Insulating Glass (Annealed) Frame: W-4880mm(192.13") H-914mm(36") Vents : W-1172mm(46.13") H-876mm(34.50") DLO: W-1057mm(41.63") H-762mm(30")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG50 4880 x 914* (192 x 36*)-AP Design Pressure: ±2400 Pa (±50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: L0563.02-301-47/NCTL-310-19-108/J8500.01-303-44
Expiration Date: November 30, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122