

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014630.06  
DATE: 05/24/2021  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Auraline" Composite</b> <b>Awning Window</b> <b>(w/ or w/o Nail Fin)</b>  Configuration: O/XO Glazing: Insulating Glass (Annealed)  Frame: W-2438mm(96") H-2438mm(96") Vent: W-1175mm(46.25") H-867mm(34.13") DLO: W-1060mm(41.75") H-2286mm(90")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class R-PG35 2438 x 2438 (96 x 96)-AP</b> <b>Design Pressure: ±1680 Pa (35 psf)</b> <b>Positive Design Pressure: 1680 Pa (35 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf)</b>

Product Tested By: Intertek, PLC  
Report No: M2333.01-301-47/NCTL 310-19-122  
Expiration Date: March 31, 2030

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122