

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014741.01-R1  
**DATE:** 03/05/2020  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 04/15/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Auraline" Composite</b> <b>Four Wide Casement Window</b>  (w/ or w/o Nail Fin)  Configuration: XXXX Glazing: Insulating Glass (Annealed)  Frame: W-3658mm(144") H-1829mm(72") Vent: W-860mm(33.88") H-1781mm(70.13") DLO: W-752mm(29.63") H-1673mm(65.88")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>CSA A440S1-17</b>	<b>Class LC-PG35 3658* x 1829* (144 x 72*)-C</b> <b>Design Pressure: ±1680 Pa (35 psf)</b> <b>Positive Design Pressure: 1680 Pa (35 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A2</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-310-20-037/J8499.01-303-44  
Expiration Date: **February 28, 2030**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122