

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014524.05-R1
DATE: 01/21/2020
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 01/22/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601 | Series "Auraline Composite" Fixed Window w/Track Filler (w/Nail Fin) Configuration:O Glazing: Insulating Glass (Annealed) Frame: W-1830mm(72.06") H-1829mm(72") DLO: W-1745mm(68.69") H-1746mm(68.75") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 | Class LC-PG50 1830 x 1829 (72 x 72)-FW Design Pressure: ±2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Canadian Air Infiltration/Exfiltration Level: Fixed |

Product Tested By: Intertek, PLC
Report No: K0788.01-301-47
Expiration Date: October 31, 2029

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122