

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014524.12  
**DATE:** 12/14/2020  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>JELD-WEN</b></p> <p><b>3737 Lakeport Boulevard</b></p> <p><b>Klamath Falls, OR 97601</b></p>	<p><b>Series "Auraline Composite"</b></p> <p><b>Fixed Picture Window w/Track Filler</b></p> <p><b>(w/Nail Fin or Thru Frame)</b></p> <p>Configuration: O                      Glazing: Insulating Glass (Annealed)</p> <p>Frame: W-2438mm(96")      H-2438mm(96")                      DLO: W-2350mm(92.50")      H-2350mm(92.50")</p>

SPECIFICATION	PRODUCT RATING
<p><b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>  <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b></p>	<p><b>Class LC-PG35 2438 x 2438 (96 x 96)-FW</b>  <b>Design Pressure: 1680 Pa (35 psf)</b>  <b>Positive Design Pressure: 1680 Pa (35 psf)</b>  <b>Negative Design Pressure: 1920 Pa (40 psf)</b>                      Water Penetration Resistance Test Pressure: 580 Pa (12.00 psf)                      Canadian Air Infiltration/Exfiltration Level: Fixed</p>

Product Tested By: Intertek, PLC  
 Report No: L6660.01-301-47  
 Expiration Date: **December 31, 2030**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
 MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
 Fax: (804) 684-5122