

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015420
DATE: 08/31/2021
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Auraline" Composite Stationary Casement Window (w/Nail Fin or Stationary Strap) Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-2134mm(84") H-2134mm(84") Panel: W-2089mm(82.25") H-2089mm(82.25") DLO: W-1978mm(77.88") H-1978mm(77.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG35 2134 x 2134 (84 x 84)-FW Design Pressure: ±1680 Pa (±35 psf) Positive Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-21-016
Expiration Date: **June 30, 2030**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com