

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014631-R1
DATE: 01/21/2020
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 01/22/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Auraline" Composite Single Hung Window (w/ or w/o Nail Fin) Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2438mm(96") Sash: W-1153mm(45.375") H-1202mm(47.375") DLO: W-1067mm(42") H-1114mm(43.875")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class LC-PG35 1219 x 2438 (48 x 96)-H Design Pressure: ±1680 Pa (35 psf) Positive Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-19-135
Expiration Date: November 30, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'Shirley'.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122