

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014948  
**DATE:** 08/31/2020  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Composite SLSH w/ CHS Transom"</b> <b>Composite Single Hung Window</b> <b>(w/ Nail Fin or Thru-Frame)</b>  Configuration: O/O/X Glazing: Insulating Glass (Annealed)  Frame: W-1220mm(48.06") H-3048mm(120") Sash: W-1156mm(45.50") H-1043mm(41.06") DLO: W-910mm(35.81") H-826mm(32.50")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG35 1220 x 3048 (48 x 120)-H</b> <b>Design Pressure: ±1680 Pa (35 psf)</b> <b>Positive Design Pressure: 1680 Pa (35 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)</b>

Product Tested By: Intertek, PLC  
Report No: L0565.01-301-47/K5634.01-301-47/NCTL-310-19-135  
Expiration Date: May 31, 2030

A handwritten signature in black ink, appearing to be 'S.M.', written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122