

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015107.04
DATE: 01/06/2022
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Auraline Composite 3-Panel" Composite Horizontal Sliding Window (Nail Fin or Thru Frame) Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2724mm(107.75") H-2134mm(84") Panel: W-895mm(35.25") H-2070mm(81.5") DLO: W-851mm(33.5") H-1978mm(77.87")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class LC-PG35 2724 x 2134 (108 x 84)-HS Design Pressure: ±1680 Pa (±35 psf) Positive Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-21-034/M9714.01-301-47
Expiration Date: **December 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com