

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 110 - 129.0
Issue Date: 4/14/2020
Revision Date: 12/7/2020
Expiration Date: 4/14/2024
Company Code: 110

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information: Solatube International, Inc 2210 Oak Ridge Way Vista, CA 92081-8341 USA	Product Information: Model: Low Profile Glass Tubular Daylight Device Operator Type: TDD Config: No, GS - 3/8" Lami Glass + 1/8" Acrylic Max Width: 15 Max Height: 15
Referenced Standard: PA/TAS 201/202/203	Product Rating: Large Missile, DP +/-100, 15x15, Struct=+/-200
Qualifying Test Information:	
Test Report No: Test Report Expiration:	ATI-J2410.02-303-44-R1 4/14/2024

Authorized Signature:

Keystone Certifications, Inc.
145 Limekiln Rd. Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501