



Mr. Erin Eilers
Fyre-Tec
701 Centennial Rd
Wayne, NE 68787, US

Our Reference:	File R21803	Project Number	4789671428
Project Scope:	Letter Report for Series 900P. Operable, horizontal slider.		

Dear Mr. Eilers,

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

This letter is to report that UL has reviewed the ratings for Fyre-tec Series 900P, and concluded the following ratings and standards are acceptable:

Model/Series	Test Method	Ratings
Series 900P horizontal sliding window	AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG50 (size tested 72 x 60) – HS (75 psf)

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

Should you have any questions or comments concerning the above, please feel free to contact the undersigned.

Sincerely,	Reviewed by:
Richard Legrand	Dave Stammen
Senior Project Engineer	PDE
Department: 3019AFPD	
Tel: 8476642123	
E-mail: Richard.Legrand@ul.com	