

CERTIFICATE OF COMPLIANCE

Certificate Number 20170915-R21803
Report Reference R21803-20040807
Issue Date 2017-SEPTEMBER-15

Issued to: D V FYRE-TEC INC
PO BOX 608
PENDER NE 68047

This is to certify that representative samples of PRODUCTS FOR USE IN WINDSTORM-RATED ASSEMBLIES, WINDSTORM-RATED ASSEMBLIES SEE NEXT PAGE

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: AAMA/WDMA/CSA101/I.S2/A440-11-North America Fenestration Standard/Specification for Windows, Doors and Skylights

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20170915-R21803
Report Reference R21803-20040807
Issue Date 2017-SEPTEMBER-15

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Series 925P wind resistant window assemblies meeting the requirements for windows tested in accordance with ANSI/AAMA/NWWDA 101/I.S.2-97 or AAMA/WDMA/CSA 101/I.S.2/A440-11. Product is able to bear a as H-R55 (48 x72) based on the 97 edition ANSI/AAMA/NWWDA 101/I.S.2 or Class R-PG55 – Size Tested 48 x 72 in - Hung (DP = +/- 55 psf) rating based 2011 edition of AAMA/WDMA/CSA 101/I.S.2/A440-11.

FRAME SIZES:

This procedure covers single hung window assemblies up to 4 ft. wide by 6 ft. high with the following:

- Maximum individual sash size of 3 ft. 8-7/16 in. wide by 2 ft. 10-11/16 in. high
- Maximum screen size of 3 ft. 8-1/4 in. wide by 2 ft. 9-13/16 in. high.
- Area of assembly not to exceed 24 sq. ft



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

