



Mr. Erin Eilers
Fyre-Tec
701 Centennial Rd
Wayne, NE68787, US

Our Reference:	File R21803	Project Number	4789714403
Project Scope:	Letter Report for Series 925P. Operable, single hung.		

Dear Mr. Eilers,

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

This letter is to report that UL has reviewed the ratings for Fyre-tec Series 925P, and concluded the following ratings and standards are acceptable:

Model/Series	Test Method	Ratings
Series 925P steel single hung window	AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG55 Size Tested 48 x 72 in - Hung (DP = +/- 55 psf)
Series 925P steel single hung window	AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG55 Size Tested 48 x 72 in - Hung (DP = +/- 55 psf)
Series 925P steel single hung windows, mullied	AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG55 Size Tested 72 x 72 in - Hung (DP = +/- 75 psf)

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

Should you have any questions or comments concerning the above, please feel free to contact the undersigned.

Sincerely,	Reviewed by:
Richard Legrand	Dave Stammen
Senior Project Engineer	PDE
Department: 3019AFPD	
Tel: 8476642123	
E-mail: Richard.Legrand@ul.com	