

CERTIFICATE OF COMPLIANCE

Certificate Number 20170918-R21803
Report Reference R21803-20040808
Issue Date 2017-SEPTEMBER-18

Issued to: D V FYRE-TEC INC
PO BOX 608
PENDER NE 68047

This is to certify that representative samples of PRODUCTS FOR USE IN WINDSTORM-RATED ASSEMBLIES, WINDSTORM-RATED ASSEMBLIES
SEE NEXT PAGE

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/AAMA/NWDA 101/I.S.2-97 or AAMA/WDMA/CSA 101/I.S.2/A440-11-North America Fenestration Standard/Specification for Windows, Doors and Skylights

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20170918-R21803
Report Reference R21803-20040808
Issue Date 2017-SEPTEMBER-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Series 950P wind resistant window assemblies meeting the requirements for windows tested in accordance with ANSI/AAMA/NWWDA 101/I.S.2-97 or AAMA/WDMA/CSA 101/I.S.2/A440-11. Product is able to bear a F-HC75 (72 in. x 72 in.) based on the 97 edition ANSI/AAMA/NWWDA 101/I.S.2 or Class CW-PG55 Size Tested 72 x 72 in - FW (DP = +/- 55 psf) rating based 2011 edition of AAMA/WDMA/CSA 101/I.S.2/A440-11.

FRAME SIZES:

This procedure covers fixed window assemblies with multiple lights up to 6 ft. wide by 6 ft. high with the following:

Single Pane Construction – 1997 edition of ANSI/AAMA/NWWDA 101/I.S.2

- Maximum individual lite size of 2 ft. 9 in. wide by 2 ft. 9 in. high.
- Each window can be divided into four individual lites
- Area of assembly not to exceed 36 sq. ft.

Double Pane (Insulated Glazing) Construction – 2011 edition of ANSI/AAMA/NWWDA 101/I.S.2/A440-11

- Maximum individual lite size of 44-1/4 in. wide by 56-1/4 in. high.
- Each 72 in. wide by 72 in. high window can be divided into of four individual lites separated by muntins
- Area of assembly not to exceed 36 sq. ft.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

