

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013365-R2
DATE: 09/09/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 09/08/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "V300" Vinyl Awning Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-813mm(32") H-1524mm(60") Vent: W-600mm(23.63") H-1356mm(53.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG50 813 x 1524 (32 x 60)-AP Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: F9421.01-801-47/F9421.01-801-47(Gateway)/W-1823
Expiration Date: **June 30, 2030**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122